

SECTION 115000  
LAMINATE CLAD CASEWORK – LABORATORY

PART 1 – GENERAL

1.01 SECTION INCLUDES

- A. Fixed modular laminate clad casework and components.
- B. Flexible rail mounted laminate clad casework and components.
- C. Countertops.
- D. Mobile storage units, tables and components.

1.02 RELATED SECTIONS

- A. Blocking within walls where indicated: Division 6.
- B. Millwork, trim, and custom cabinetry: Division 6.
- C. Locks master keyed to room doors: Division 8.
- D. Glass: Division 8.
- E. Base molding: Division 9.
- F. Appliances: Division 11.
- G. Sinks and service fixtures, service waste lines, connections, and vents: Division 15.
- H. Electrical service fixtures: Division 16.

1.03 DEFINITIONS

- A. Identification of casework components and related products by surface visibility.
  - 1. Open Interiors: Any open storage unit without solid door or drawer fronts, units with full glass insert doors and/or acrylic doors, and units with sliding solid doors.
  - 2. Closed Interiors: Any closed storage unit behind solid door or drawer fronts.
  - 3. Exposed Ends: Any storage unit exterior side surface that is visible after installation.
  - 4. Other Exposed Surfaces: Faces of doors and drawers when closed, and tops of cabinets less than 72 inches above furnished floor.
  - 5. Semi-Exposed Surfaces: Interior surfaces which are visible, bottoms of wall cabinets and tops of cabinets 72 inches or more above finished floor.
  - 6. Concealed Surfaces: Any surface not visible after installation.

1.04 QUALITY ASSURANCE

- A. Manufacturer: Minimum of 5 years experience in providing manufactured casework systems for similar types of projects, produce evidence of financial stability, bonding capacity, and adequate facilities and personnel required to perform on this project.
- B. Manufacturer: Provide products certified as meeting or exceeding ANSI-A 161.1-2000 testing standards.
- C. Single Source Manufacturer: Casework, countertops and architectural millwork products must all be engineered and built by a single source manufacturer in order to ensure consistency and quality for these related products. Splitting casework, countertops and/or architectural millwork between multiple manufacturers will not be permitted.
- D. Manufacturer: Provide products meeting or exceeding SEFA 8 PL-2007 Recommended Practices for Plastic Laminate Laboratory Grade Furniture, Casework, Shelving and Tables, as established in the Scientific Equipment & Furniture Association (SEFA) 2008 Desk Reference, 3rd Edition
- E. Quality Standard: Unless otherwise indicated, comply with AWI's Architectural Woodwork Quality Standards for grades of interior architectural woodwork, construction, finishes and other requirements.
  - 1. Provide AWI Quality Certification Program LABELS indicating that the woodwork complies with requirements of the grade specified. This project has been registered as AWI/QCP project number (ENTER NUMBER HERE).
  - 1. Provide AWI Quality Certification Program CERTIFICATE indicating that the woodwork complies with requirements of the grade specified. This project has been registered as AWI/QCP project number (ENTER NUMBER HERE).
  - 1. The contractor, upon award of work, shall register the work under this section with the AWI Quality Certification Program (Phone: 800.449.8811).

1.05 SUBMITTALS

- A. Comply with Section 01330, unless otherwise indicated.
- B. Product Data: Manufacturer's catalog with specifications and construction details.
- C. Shop Drawings: Indicate dimensions, description of materials and finishes, general construction, specific modifications, component connections, anchorage methods, hardware, and installation procedures, plus the following specific requirements.
  - 1. Include section drawings of typical and special casework, work surfaces and accessories.

2. Indicate locations of plumbing and electrical service field connection by others.
  3. Provide one set of shop drawings which includes all products within this section, engineered and built by a single source manufacturer, with seamless coordination amongst all products.
- D. Casework Samples (To be available upon request):
1. Base cabinet: Cabinet conforming to specifications, with drawer and door.
  2. Wall cabinet: Cabinet conforming to specifications, with door.
  3. Cabinet samples shall be complete with specified hardware for doors, drawers and shelves.
  4. Component samples: Two sets of samples for each of the following:
    - a. Decorative laminate color charts / PVC and ABS edgings.
- 1.06 PRODUCT HANDLING
- A. Deliver completed laminate clad casework, countertops, and related products only after wet operations in building are completed, store in ventilated place, protected from the weather, with relative humidity range of 25 percent to 55 percent.
  - B. Protect finished surfaces from soiling and damage during handling and installation with a protective covering.
- 1.07 JOB CONDITIONS
- A. Environmental Requirements: Do not install casework until permanent HVAC systems are operating and temperature and humidity have been stabilized for at least 1 week.
    1. Manufacturer/Supplier shall advise Contractor of temperature and humidity requirements for architectural casework installation areas.
    2. After installation, control temperature and humidity to maintain relative humidity between 25 percent and 55 percent.
  - B. Conditions: Do not install casework until interior concrete work, masonry, plastering and other wet operations are complete.
- 1.08 WARRANTY
- A. All materials and workmanship covered by this section will carry a one (1) year warranty from date of acceptance.

## PART 2 – PRODUCTS

- 2.01 ACCEPTABLE MANUFACTURERS:
- A. Manufacturer:
    1. TMI Systems Corporation.
      - a. Drawings and specifications are based on manufacturer's literature from TMI SYSTEMS CORPORATION, 50 South Third Avenue West, Dickinson, North Dakota, 58601, Phone: 800-456-6716, fixed modular, flexible rail mounted, and mobile casework and accessories.
      - b. Other manufacturers shall comply with the minimum levels of material and detailing indicated on the drawings or as specified.
- 2.02 MATERIALS
- A. Core Materials:
    1. Particleboard up to 7/8 inch thick: Industrial Grade average 45-pound density particleboard, ANSI A 208.1-2009, M-2 requirements.
    2. Particleboard 1 inch thick and thicker: Industrial Grade average 45-pound density particleboard, ANSI A 208.1-2009, M-2 requirements.
    3. Medium Density Fiberboard 1/4 inch thick: Minimum average density 45-50 lbs., ANSI A208.2-2009 requirements.
    4. MR Moisture Resistant Particleboard: Average 45-pound density particleboard, ANSI A208.1 1-2009, M-2 requirements.
  - B. Decorative Laminates: GREENGAURD Indoor Air Quality Certified
    1. High-pressure decorative laminate VGS (.028), NEMA Test LD 3-2005.
    2. High-pressure decorative laminate HGS (.048), NEMA Test LD 3-2005.
    3. High-pressure decorative laminate HGP (.039), NEMA Test LD 3-2005.
    4. Chemical-Resistant decorative laminate, NEMA Test LD 3-2005
    5. High-pressure cabinet liner CLS (.020), NEMA Test LD 3-2005.
    6. High-pressure backer BKH (.048), (.039), (.028), NEMA Test LD3-2005.
    7. Thermally fused melamine TFM laminate, NEMA Test LD 3-2005. (TFM allowed on casework interiors only, as specified below. Utilization of TFM on any exterior casework surfaces, including door and drawer faces and finished ends, will not be permitted.)

- C. Laminate Color Selection: Maximum 1 color per unit face and 5 colors per project. (See Color Selection in section 3.05).
- D. Edging Materials:
  - 1. 1mm PVC banding, machine applied.
  - 2. 3mm PVC banding, machine applied and machine profiled to 1/8 inch radius.
- E. Glass:
  - 1. Wall unit full sliding glass doors: 1/4 inch thick laminated safety glass.
  - 2. Glass insert doors, hinged or sliding wall cabinets: 1/4 inch thick laminated safety glass.
  - 3. Glass insert doors, hinged or sliding tall or base cabinets. 1/4 inch thick laminate safety glass.
  - 4. Sliding doors mounted in aluminum track.
  - 5. Trim glass inserts: Extruded rigid PVC channel and self-locking insert retainer strip.

## 2.03 SPECIALTY ITEMS

- A. Support Members:
  - 1. Countertop support brackets: Epoxy powder coated, 11 gauge steel with integral cleat mount opening and wire management opening.
  - 2. Undercounter support frames: Epoxy powder coated.
  - 3. Legs: Epoxy powder coated.
- B. Mobile Storage Units:
  - 1. Mobile storage units are mounted to a caster base panel.
  - 2. Casters: 5 inch soft rubber double ball bearing, heavy gauge steel fork, zinc plate finish with 2 brakes per unit. Load capacity per caster to be a minimum of 200 pounds.
  - 3. Side panels, back, top, door and drawer fronts are of 3/4 inch thick particleboard, laminated on the exterior with VGS (0.028") high pressure decorative laminate and balanced on the interior with CLS (0.020") high pressure cabinet liner. Use of TFM on exposed exterior surfaces or interior surfaces will not be permitted.
  - 4. Exposed edges are PVC banding, 1mm or 3mm thickness, to match adjacent casework.
- C. Computer Keyboard Tray:
  - 1. Non-articulating, undercounter mount with positive stop drawer slides.

## 2.04 CABINET HARDWARE

- A. Hinges:
  - 1. Five knuckle, brushed stainless steel, institutional grade, 2-3/4 inch overlay type with hospital tip. 0.095 inch thick. ANSI-BHMA standard A156.9, Grade 1.
    - a. Doors 48 inches and over in height have 3 hinges per door.
- B. Pulls:
  - 1. Select from the TMI Vendor Stock Pull Program or other manufacturer's pre-approved equivalent program.
  - 2. Pull program offering must include minimum of 20 metal pull design and finish option combinations including:
    - a. Bar Pull (Finish options: Satin Bronzed Copper, Chrome Polished, Chrome Matte, and Brushed Nickel)
    - b. Bow Pull (Finish options: Black Matte, Oil Rubbed Bronze, Satin Bronzed Copper, Chrome Polished, Chrome Matte, and Nickel Matte)
    - c. Contemporary Pull (Finish option: Brushed Nickel)
    - d. Heavy Bow Pull (Finish option: Brushed Nickel)
    - e. Petite Bow Pull (Finish option: Brushed Nickel)
    - f. Metal Wire Pull (Finish options: Epoxy Powder Coated Gray, Beige, White, Black, Slate, Chrome, and Satin Chrome US26D)
  - 3. All pulls with 96mm spacing on screws. Pull designs shall comply with the Americans with Disability Act (ADA).
- C. Drawer Slides:
  - 1. Regular, kneespace and pencil: Full extension 100-pound load rated cold rolled steel, side mounted with steel ballbearings. Featuring an easy to operate disconnect finger release system.
  - 2. File: Full extension 150-pound load rated cold rolled steel, side mounted with steel ballbearings. Featuring an easy lift-off drawer rail disconnect.
- D. Adjustable Shelf Supports:
  - 1. Injection molded transparent polycarbonate friction fit into cabinet end panels and vertical dividers, adjustable on 32mm centers. Each shelf support has 2 integral support pins, 5mm diameter, to interface pre-drilled holes, and to prevent accidental rotation of support. The support automatically adapts to 3/4 inch or 1 inch thick shelving and provides non-tip feature for shelving. Supports may be field fixed if desired. Structural load to 1200 pounds (300 pounds per support) without failure.
- E. Locks:

1. Five-pin tumbler, cam style lock with strike. Lock for sliding 3/4 inch thick doors is National #M2-3708-157 lock, National #M2-3709-100 strike and National #M5-0057-110 escutcheon plunger lock with strike. Sliding glass door lock is National #M2-0225-002 sliding showcase lock.
  2. Elbow catch or chain bolt used to secure inactive door on all locked cabinets.
- F. Sliding Door Track: Anodized aluminum double channel.
- G. File Suspension System: Extruded molding integral with top of drawer box sides to accept standard hanging file folders.
- H. Mirrors: 1/8 inch thick mirrored acrylic, break and impact resistant.

## 2.05 FABRICATION:

- A. Fabricate casework, countertops and related products to dimensions, profiles, and details shown.
- B. All casework panel components must go through a supplemental sizing process after cutting, producing a panel precisely finished in size and square to within 0.010 inches, ensuring strict dimensional quality and structural integrity in the final fabricated product.
- C. Cabinet Body Construction:
  1. Tops and bottoms are glued and doweled to cabinet sides and internal cabinet components such as fixed horizontals, rails and verticals. Minimum 6 dowels each joint for 24 inch deep cabinets and a minimum of 4 dowels each joint for 12 inch deep cabinets. (Mechanical or metal hardware fasteners joining cabinet top and bottom panels to the sides will not be accepted.)
    - a. Tops, bottoms and sides of all cabinets except sink cabinets are particleboard core.
    - b. Tops, bottoms and sides of sink base units are moisture resistant particleboard core.
  2. Cabinet backs: 1/4 inch thick medium density fiberboard panel fully captured by the cabinet top, bottom and side panels. Finish to match cabinet interior. 3/4 inch x 4 inch particleboard rails will be placed behind the back panel at the top and bottom, and doweled to the sides utilizing 10mm hardwood fluted dowels. A third intermediate rail will be included on all cabinets taller than 56 inches. Utilize hot melt glue to further secure back and increase overall strength.
    - a. Exposed back on fixed or movable cabinets: 3/4 inch thick particleboard with the exterior surface finished in VGS laminate as selected.
    - a. Exposed back on fixed or movable sink base cabinets: 3/4 inch thick moisture resistant particleboard with the exterior surface finished in VGS laminate as selected.
  3. Fixed base and tall units have an individual factory-applied base, constructed of 3/4 inch thick plywood. Base is 102mm (nominal 4 inch) high unless otherwise indicated on the drawings.
  4. Base units, except sink base units: Full sub-top glued and doweled to cabinet sides. (Mechanical or metal hardware fasteners joining cabinet sub-top panel to the sides will not be accepted.)
    - a. Sink base units are provided with open top and a stretcher at the front, attached to the sides. Back to be split removable access panel.
  5. Side panels and vertical dividers shall receive adjustable shelf hardware at 32mm line boring centers. Mount door hinges, drawer slides and pull-out shelves in the line boring for consistent alignment.
  6. Exposed and semi exposed edges.
    - a. Edging: 3mm PVC machine applied and machine profiled to 1/8 inch radius.
  7. Adjustable Shelves in Cabinets
    - a. Core: Particleboard.
    - b. Core Thickness: 3/4 inch up to 30 inches wide, 1 inch over 30 inches wide.
    - c. Edge: 3mm PVC on Front & Back Edges, 1mm PVC on Side Edges.
  8. Interior finish, units with open Interiors:
    - a. Top, bottom, back, sides, horizontal and vertical members, and adjustable shelving faces with TFM Thermally Fused Melamine laminate.
  9. Interior finish, units with closed Interiors:
    - a. Top, bottom, back, sides, horizontal and vertical members, and adjustable shelving faces with TFM Thermally Fused Melamine laminate.
  10. Exposed ends:
    - a. Faced with Chemical Resistant high-pressure decorative VGS laminate. Use of TFM on exposed ends will not be permitted.
  11. Wall unit bottom:
    - a. Faced with thermally fused melamine laminate.
  12. Balanced construction of all laminated panels is mandatory. Unfinished core stock surfaces, even on concealed surfaces (excluding edges), are not permitted.
- D. Drawers:

1. Sides, back and sub front: Minimum 1/2 inch thick particleboard, laminated with TFM Thermally Fused Melamine, doweled and glued into sides. Top edge banded with 1mm PVC.
  2. Drawer bottom: Minimum 1/2 inch thick particleboard laminated with TFM Thermally Fused Melamine, screwed directly to the bottom edges of drawer box.
- E. Door/Drawer Fronts:
1. Core: 3/4 inch thick particleboard except at sink units which are 3/4 inch thick moisture resistant particleboard.
  2. Chemical Resistant high-pressure decorative VGS laminate exterior, balanced with high-pressure cabinet liner CLS. Use of TFM on exterior or interior surfaces of door/drawer fronts will not be permitted.
  3. Edges: 3mm PVC, machine applied, external edges and outside corners machine profiled to 1/8 inch radius.
  4. Provide double doors in opening in excess of 24 inches wide.
- F. Miscellaneous Shelving (not in Cabinets):
1. Core material: 1 inch thick particleboard.
  2. High-pressure decorative VGS laminate on both faces.
  3. Edges: 3mm PVC, external edges and outside corners machine profiled to 1/8 inch radius.
- F. Reagent and Wall Shelving:
1. Core material: 1 inch thick plywood.
  2. Chemical Resistant high-pressure decorative VGS laminate on both faces.
  3. Edges: 3mm PVC, external edges and outside corners machine profiled to 1/8 inch radius. Front edge reagent 'lip' to be raised above the shelf 3/8 inch.
- 2.06 DECORATIVE LAMINATE COUNTERTOPS:
- A. Core:
1. All countertops except at sink elevations: 1-1/8 inch thick ANSI A208.1-1993 M-2 particleboard.
  2. Countertops at sink elevations: 1-1/8 inch thick ANSI A208.1-1993 M-3 moisture resistant (MR) particleboard.
- B. Surface: Chemical Resistant high-pressure decorative HGS/HGP laminate with balanced backer sheeting.
- C. Edges, including applied backsplash: 3mm PVC, exposed edges and corners machine profiled to 1/8 inch radius.
- D. All countertops joints must be dry fit at the factory to check for consistency in color from one panel to the other and overall finished panel thickness, resulting in a high quality product easy to install.
- 2.07 HEAVY DUTY TABLES:
- A. Work tops: 1 inch thick particleboard core laminated top surface with HGS/HGP laminate, balanced with backer sheeting.
1. Edges: 3mm PVC
- B. Work top support frame: Furniture grade, epoxy powder coated steel.
- C. Under table storage units: Manufacturer's flexible rail mounted undercounter units adapted for installation to work top support frame.
- D. Adjustable legs: 1-3/4 inch x 1-3/4 inch x 14 gauge epoxy powder coated tubing fitted inside 2 inch x 2 inch x 14 gauge with height adjustment.
1. Heavy-duty, non-marking adjustable floor glides.
- 2.08 UTILITY CHASE SYSTEM
- A. Flexible rail utility chase frames: Internal epoxy powder coated steel frame assembly pre-drilled to accept other system components. Dimensionally integrated to align with and accommodate fixed modular or flexible rail-mounted casework and countertops.
- B. Flexible rail mounted casework support rail and interfacing support keys:
1. Extruded aluminum 6061-T6 alloy, epoxy powder coated, concealed structural fasteners secured through portion of closure panel one or both sides as required.
- C. Chase access panels: 3/4 inch thick with 1mm PVC edges, thermally fused melamine laminate faces both sides.
- D. Wing walls: 1 inch thick particleboard with high-pressure decorative laminate VGS both sides, 3mm PVC edges, two levelers on bottom edge.
- E. Reagent ledges and over-chase shelving: 1 inch thick particleboard with 3mm PVC edges; provide laminate surfaces as indicated.

## PART 3- EXECUTION

### 3.01 INSPECTION:

- A. The casework contractor must examine the job site and the conditions under which the work under this section is to be performed, and notify the building owner in writing of unsatisfactory conditions. Do not proceed with work under this Section until satisfactory conditions have been corrected in a manner acceptable to the installer.
- 3.02 PREPARATION:
- A. Condition casework to average prevailing humidity conditions in installation areas prior to installing.
- 3.03 INSTALLATION:
- A. Erect casework, plumb, level, true and straight with no distortions. Shim as required. Where laminate clad casework abuts other finished work, scribe and cut to accurate fit.
  - B. Adjust casework and hardware so that doors and drawers operate smoothly without warp or bind.
  - C. Repair minor damage per plastic laminate manufacturer's recommendations.
- 3.04 CLEANING:
- A. Remove and dispose of all packing materials and related construction debris.
  - B. Clean cabinets inside and out. Wipe off fingerprints, pencil marks, and surface soil etc., in preparation for final cleaning by the building owner.
- 3.05 COLOR SELECTION:
- A. Laminate Color Selection:
    - 1. Select from the full range of standard Wilsonart® and Formica® stock color charts.
    - 2. Thermally fused melamine laminate matched to White color.
  - B. Hardware Color Selection:
    - 1. Hinge: Brushed stainless steel finish.
    - 2. Pulls: Select from design specific finish options available in the TMI Vendor Stock Pull Program.
    - 3. Miscellaneous Hardware (support brackets, metal components, etc.): Select from your choice of epoxy powder coating stock colors matched to White, Beige, Gray, Black, Slate and Chrome.
  - C. PVC Edge Banding Color Selection:
    - 1. 3mm PVC: Select from your choice of stock colors matched to White, Beige, Gray, Black and Slate. Other colors are available\*. Special order colors may impact cost and lead times.
    - 2. 1mm PVC: Select from your choice of stock colors matched to White, Beige, Gray, Black and Slate. Other colors are available\*. Special order colors may impact cost and lead times.

\*For complete and current Laminate and PVC color availability charts please refer to:

<http://www.tmisystems.com>

## **Manufactures**

General: Products based on casework manufactured by TMI.

Contact: [sales@bradfordsystems.com](mailto:sales@bradfordsystems.com) or by phone: 800-696-3453

29 September 2017  
END OF SECTION